

*At Haydenville, Ohio,
7 Miles S.E. of Logan.*

Fire Proofing 10' high.

Fire Proofing 10' high.

PLANT No. 1, ON
OLD PLANT.

NO NAME

PLANT No. 2 OR NEW PLANT

H. V. R. R. SIDING.

*THE COLUMBUS BRICK &
TERRA COTTA CO.*

NO REGULAR WATCHMAN, EMER AT GUTHRIE KILNS AND 1 MIN AT ENDS AM DURING NIGHT, NO CLOCK. W.T., 10,000 GALS CAPY ON HILL 80' ABOVE AND 150' EAST OF PLANT, FILLED BY LAIDLAY QUINN PUMP (SIZE 8" X 8" X 12") FROM DEEP WELL, 5' LINE TO TANK. NO DIRECT PRESSURE, 450-25' HGS AT PLANT. LIGHTS: ELECT. (DOWN DYNO) HEAT: COAL CLOS. FUEL: COAL IN BLAS - WOOD & COAL IN KILNS. NO DRY HO'S AS BRICKS MADE HERE ARE DRY PRESSED.

*At Union Furnace, Ohio,
7 Miles S. of Logan.*

Scale of Feet

Map Division
Aug 12 '55
Library of Congress

